
Detector Control Systems

EPICS Infrastructure And Python Interfacing




Client/Server






Production & Commisioning



- Separate copies of the daemons run simultaneously with different hardware lists for Production and Commissioning
- Allows for seamless transitions between detector changes
- Common Clients can be used for both tasks

Daemon Structure





Example HAL Structure



HAL Control

Dev. Initialization

Dev. ID String

Dev. Registration List

Avail. Function Mask

Aux. Function List

Data Stack

Device Data Value Data Value Type

Address Translation

Universal Query

Address Query

Hardware Address Map

Universal Chan Hardware Address

Universal Chan Hardware Address

Universal Chan Hardware Address

Function Stack

Device ON

Device OFF

Channel ON

Channel OFF

Channel GET

Channel SET

Alarm Check


Alarm Set

Etc.....



Client Structure






Implementation



- Choosing an implementation has focused on three external goals in addition to the detector requirements, to:
 - Minimize Cost
 - Minimize Development time
 - Retain flexibility and expandability
- Choosing an existing Detector Controls infrastructure appears to be the best way to meet these.
- Use:
 - EPICS Detector controls, client/server protocol, internal data representation
 - Python Cross platform Scripting interface with good EPICS support/hooks for device control
 - TKInter TCL/TK GUI set for building the graphical interfaces with Python
 - ROOT Additional GUI and visualization for data quality/monitoring

Example Implementation






EPICS Infrastructure



- EPICS (Experimental Physics and Control Systems) developed by Argonne National Lab is based on a server/client model similar to that which we desire for NOvA
- Provides Infrastructure
 - Network Protocol
 - Database handling
 - Data processing
 - Hooks for common apps
 - ■Python, Perl, C/C++



EPICS Advantages



- Cost It is free!
- Protocols and Database management already developed and well documented.
- Runs on multiple platforms including PC/Linux
- Used in other large scale experiments, and is well supported by the labs.
- Device drivers for certain "common" instruments already exist.
 - i.e. Tek Oscilloscopes, generic CAMAC devices, FNAL beam monitors etc...
- Monitoring and data quality tools already exist and can be adapted
- Tool kits are available to allow for interface of the EPICS base with external packages (i.e. GUI development)

EPICS Disadvantage




- Requires development of dedicated I/O control drivers for each custom device we want to monitor or control
- Requires all clients and servers to be physically on the same local network (i.e. no direct off-site client access)
- Relies on global broadcasts for client/server communication which complicates partitioning of the experiment into "Production" and "Test" segments
 - But there is docs on how to do this
- I/O Controller setup is targeted more towards direct hardware access than to high latency network access
 - But can write custom IOCs to do this
- Client access is via individual record requests, not large block requests
 - Inefficient for monitoring LARGE numbers of channels
 - Ways around this with custom "record" design etc...

Channel Access Example



Example:

Get the value of a high voltage channel for monitoring. (Module 34, Channel 3) Call the channel "Module 34: HV3: Voltage" and make the following requests:



EPICS Performance



- Performance depends upon efficient implementation of device drivers for I/O controllers, and sequencer vs. database operation modes
- Benchmarks from Argonne*:

Machine	OS	CPU	Speed	Rec/sec	%CPU
MVME16 7	vxWor ks	68040	33MHz	6000	50
MVME 2306	vxWor ks	PPC604	300MHz	10000	10
MVME51 00	vxWor ks	PPC750	450MHz	40000**	10**
PC	Linux	PII	233MHz	10000	27
PC	Linux	P4	2.4GHz	50000	9

This is what we can expect

^{*}Benchmark figures courtesy of Steve Hunt (PSI)

^{**}Extrapolated from performance figures provided by L.Hoff, BNL

Projected Performance



- Assuming device drivers similar to the ANL test setup and hardware access times/topology, we can expect:
 - $\sim 50,000$ data values processed per server per second.
 - Assumes we want to retain a "safe" cpu load (10-20% average)
 - Assumes EPICS operating in simple database mode
- More realistic Implementation of EPICS control systems at $D\emptyset$
 - Central Fiber Tracker (CFT):
 - 1 channel server per 20 DFEAII boards
 - Run on 1GHz processor linux computer using gigabit fiber to access crate
 - Monitor and control ≈ 800 values @ 1Hz with 2% cpu load*
 - Simple linear scaling up to 50k variables and a 3GHz processor
 - Expected cpu load ≈ 42%

Note: This is "database" mode not monitoring state machine mode

CPU load average per 50k data $\approx 10-50\%$

Monitoring Load



System	Values	Channels	Total
Low Voltage	6	81	486
High Voltage	2	162	324
DCMs	≈ 20	324	6480
Water Cooling	≈ 16	144	2304
Environmental	100-400		100-400
FEBs (via DCMs)	10-20	20,000	400k
	9984		
		TOTAL	410k w/FEBs

- Monitoring load is computed both with and without individual FEB operational parameters included in the monitoring stream.
- Bandwidth per monitoring cycle from raw devices to channel access servers (w/o FEBs) should be \sim 1MByte after overhead

| Monitoring Cycle




- Without FEB monitoring, we expect to control and monitor on the order of 10k operational parameters.
- We can use the EPICS state machine functionality instead of the simple database records and remain within the CPU budget
- If the hardware allows, it will be possible to readout and perform **continuous** state monitoring at the channel server level (e.g. 1Hz monitoring cycle)
- Periodic state reporting between client and server can be scheduled for database recording, trend plotting, data quality analysis etc...
- Detection of faults can be reported immediately to the monitoring clients instead of waiting for a client initiated request on a slow cycle

Computing Resources



- It should be possible to monitor the base 10k operational parameters from one server
- For fault tolerance we should break the load between multiple servers, each servicing a subset of the monitoring subsystems, and configured to provide fall over redundancy



FEB Monitoring in EPICS



- If we include the FEB operational parameters then we need to expand the number of monitoring nodes to accommodate the load
- At a monitoring frequency of 1Hz this means 400k parameters
- This means 8 monitoring stations minimum, 10 with double fault fall over redundancy

Options:

- Can reduce the monitoring frequency
- Level the FEB monitoring/status information in the primary data stream

Montoring	Channels	Base Computing	Fall Over Redundancy	Total
Base Op. Parameters	10k	1	Double fault	3
Base + FEBs	410k	9	Double fault	11

Computing Costs



- Monitoring server requirements are based on a system capable of processing 50k records per second
 - 3 GHz processor class Linux PC
 - Large (2 GB) system memory to aid internal database speed
 - Gigabit network
 - 1U rack mount

Monitoring	Monitoring Servers	Cost Per Station	Total Cost
Integration Prototype	1	2200	2.2k
Base Op. Parameters	3	2200	6.6k
Base + FEBs	11	2200	22k

Monitoring Clients



- Clients are easier!
- Each client can be a dedicated interface to a set of EPICS controlled parameters
- Clients are written in Python with EPICS libraries and TK widget sets for graphical elements (this is similar to DØ)
- This makes clients:
 - Portable and platform independent
 - Easy to modify and maintain
 - Gives reasonable performance
- Clients required to do more intensive processing are written in in C++ using the EPICS libraries and ROOT interface/widgets for visualization
- Logging and database operation can be done in either model using the standard C++ or Python interfaces to MySQL etc...

Client Development



- Monitoring clients can be developed independent of the channel servers because they use the EPICS protocol and standard calls for communications
- This means client and server development can begin in parallel
- Client/Server integration testing can be performed with mock servers that used "dummy" device drivers to generate data streams
 - This means software development can begin prior to hardware acquisition
 - Software is insulated from hardware changes

Server Development



- The channel servers (I/O controllers) need to be written in C/C++ with EPICS libraries.
- Custom device drivers will have to be developed for each system we wish to monitor. This means:
 - High Voltage system (CAEN)
 - Low Voltage systems (Wiener)
 - Data Concentrators Modules
 - Water and Cooling
 - Environmental
- Most of these systems will be capable of communicating over Ethernet using IP, which will simplify driver development, but each system will need a dedicated driver.
- The server infrastructure is independent of the device and can be developed without the hardware
- The device drivers NEED example hardware for development and testing
- For the integration prototype this means we need to know the hardware decisions with some lead time to have fully functional monitoring in place

Client/Server Resources (Development)



Monitoring/Control client and server development can proceed in parallel

Task	Time Span	Personnel	FTE
Integration Prototype Monitoring clients and servers	1.0	1	1.0
Production monitoring, Control, Logging clients	1.5 years	0.5	0.75
Production Channel servers (HV, LV, DCM, FEBs, etc)	2.5 years*	0.25	0.75
Continued Maint, Service, Updates	5 years	0.125	0.625

^{*}Hardware development dependent